



## ALTERNATE MACHINE ROOM LAYOUT

NOTE: ALL DIMENSIONS ARE APPROXIMATE

1. 220 V, 2 POLE, SINGLE PHASE, FUSED DISCONNECT WITH 30 AMP RK-5 FUSES (PER NEC 2002-BY OTHERS) ALSO, PROVIDE 120 V, FUSED DISCONNECT OR 15 AMP CIRCUIT BREAKER FOR CAB LIGHTS (PER NEC 2002-BY OTHERS).
2. PROVIDE A PHONE LINE TO THE ELEVATOR MACHINE ROOM AND INSTALL IN A 4" x 4" BOX WITH COVER (8'-10" TAIL MINIMUM) (BY OTHERS).
3. LIGHT SWITCH TO BE INSTALLED ADJACENT TO LOCK SIDE OF THE DOOR (BY OTHERS).
4. MACHINE ROOM DOOR TO BE A MINIMUM OF 30" WIDE. MACHINE ROOM DOORS TO SWING OUTWARD (BY OTHERS).
5. A GFI RECEPTACLE IS TO BE PROVIDED IN THE ELEVATOR MACHINE ROOM/SPACE (PER NEC 2002-BY OTHERS).
6. 5'-0" MINIMUM HEADROOM REQUIRED FOR ELEVATED PLATFORM STANDS.
7. CONTROLLER IS WALL MOUNTED ABOVE PUMPING UNIT. DIMENSIONS 20" W x 20" H x 6"D WITH BOTTOM OF CONTROLLER 4'-0" ABOVE FLOOR (TYPICALLY).


**SOUTHEASTERN  
ELEVATOR**  
 ELEVATORS & MOBILITY SOLUTIONS

877-720-0075

JOB NAME:

**SPECIFICATIONS**

DRAWING NO:

**CL-HYD LM02**